

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-WC-01-Hall1 Lims Reference ID: AC30604-02 Matrix: Drinking Water Sampled: 09/07/24 09:02:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-BF-01-Hall1 Lims Reference ID: AC30604-03 Matrix: Drinking Water Sampled: 09/07/24 09:03:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Kit1 Lims Reference ID: AC30604-04 Matrix: Drinking Water Sampled: 09/07/24 09:03:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Kit2 Lims Reference ID: AC30604-05 Matrix: Drinking Water Sampled: 09/07/24 09:04:00									
<b>Metals</b>									
Lead	1.43		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-KF-01-KIT Lims Reference ID: AC30604-06 Matrix: Drinking Water Sampled: 09/07/24 09:05:00									
<b>Metals</b>									
Lead	152		5	5.00	µg/L	09/26/24 14:50	09/27/24 16:27	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: CSES-SO-01-FAC Lims Reference ID: AC30604-07 Matrix: Drinking Water Sampled: 09/07/24 09:06:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-Rm119 Lims Reference ID: AC30604-08 Matrix: Drinking Water Sampled: 09/07/24 09:07:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-Rm119 Lims Reference ID: AC30604-09 Matrix: Drinking Water Sampled: 09/07/24 09:08:00									
<b>Metals</b>									
Lead	1.21		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm120 Lims Reference ID: AC30604-10 Matrix: Drinking Water Sampled: 09/07/24 09:10:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:20	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-01-Rm120 Lims Reference ID: AC30604-11 Matrix: Drinking Water Sampled: 09/07/24 09:10:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm121 Lims Reference ID: AC30604-12 Matrix: Drinking Water Sampled: 09/07/24 09:12:00									
<b>Metals</b>									
Lead	9.08		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm121 Lims Reference ID: AC30604-13 Matrix: Drinking Water Sampled: 09/07/24 09:12:00									
<b>Metals</b>									
Lead	1.10		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm122 Lims Reference ID: AC30604-14 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	1.41		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm122 Lims Reference ID: AC30604-15 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	1.03		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm123 Lims Reference ID: AC30604-16 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm123 Lims Reference ID: AC30604-17 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	1.75		1	1.00	µg/L	09/26/24 18:04	09/27/24 14:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm124 Lims Reference ID: AC30604-18 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	1.53		1	1.00	µg/L	09/26/24 18:05	09/27/24 16:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm124 Lims Reference ID: AC30604-19 Matrix: Drinking Water Sampled: 09/07/24 09:13:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 16:44	PL	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-WC-01-GLR Lims Reference ID: AC30604-29 Matrix: Drinking Water Sampled: 09/07/24 09:20:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-BF-01-GLR Lims Reference ID: AC30604-30 Matrix: Drinking Water Sampled: 09/07/24 09:20:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-WC-01-BLR Lims Reference ID: AC30604-31 Matrix: Drinking Water Sampled: 09/07/24 09:21:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-BF-01-BLR Lims Reference ID: AC30604-32 Matrix: Drinking Water Sampled: 09/07/24 09:21:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-NS-01-Nurse Lims Reference ID: AC30604-33 Matrix: Drinking Water Sampled: 09/07/24 09:23:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-FAC Lims Reference ID: AC30604-34 Matrix: Drinking Water Sampled: 09/07/24 09:23:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm200 Lims Reference ID: AC30604-35 Matrix: Drinking Water Sampled: 09/07/24 09:25:00									
<b>Metals</b>									
Lead	23.1		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm200 Lims Reference ID: AC30604-36 Matrix: Drinking Water Sampled: 09/07/24 09:25:00									
<b>Metals</b>									
Lead	3.34		1	1.00	µg/L	09/26/24 18:05	09/27/24 17:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-201 Lims Reference ID: AC30604-37 Matrix: Drinking Water Sampled: 09/07/24 09:25:00									
<b>Metals</b>									
Lead	40.8		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:04	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School  
**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-02-Rm201 Lims Reference ID: AC30604-38 Matrix: Drinking Water Sampled: 09/07/24 09:25:00									
<b>Metals</b>									
Lead	3.46		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm203 Lims Reference ID: AC30604-39 Matrix: Drinking Water Sampled: 09/07/24 09:27:00									
<b>Metals</b>									
Lead	1.05		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm203 Lims Reference ID: AC30604-40 Matrix: Drinking Water Sampled: 09/07/24 09:27:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm100 Lims Reference ID: AC30604-41 Matrix: Drinking Water Sampled: 09/07/24 09:27:00									
<b>Metals</b>									
Lead	7.03		1	1.00	µg/L	09/26/24 14:50	09/27/24 15:07	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: CSES-DW-01-Rm100 Lims Reference ID: AC30604-42 Matrix: Drinking Water Sampled: 09/07/24 09:27:00									
<b>Metals</b>									
Lead	4.02		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm101 Lims Reference ID: AC30604-43 Matrix: Drinking Water Sampled: 09/07/24 09:30:00									
<b>Metals</b>									
Lead	4.45		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm101 Lims Reference ID: AC30604-44 Matrix: Drinking Water Sampled: 09/07/24 09:30:00									
<b>Metals</b>									
Lead	1.70		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm102 Lims Reference ID: AC30604-45 Matrix: Drinking Water Sampled: 09/07/24 09:30:00									
<b>Metals</b>									
Lead	2.32		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm102 Lims Reference ID: AC30604-46 Matrix: Drinking Water Sampled: 09/07/24 09:30:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:27	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School  
**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-SO-01-Rm103 Lims Reference ID: AC30604-47 Matrix: Drinking Water Sampled: 09/07/24 09:31:00									
<b>Metals</b>									
Lead	4.88		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm103 Lims Reference ID: AC30604-48 Matrix: Drinking Water Sampled: 09/07/24 09:31:00									
<b>Metals</b>									
Lead	1.73		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm204 Lims Reference ID: AC30604-49 Matrix: Drinking Water Sampled: 09/07/24 09:35:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm204 Lims Reference ID: AC30604-50 Matrix: Drinking Water Sampled: 09/07/24 09:36:00									
<b>Metals</b>									
Lead	1.70		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm205 Lims Reference ID: AC30604-51 Matrix: Drinking Water Sampled: 09/07/24 09:36:00									
<b>Metals</b>									
Lead	4.80		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm205 Lims Reference ID: AC30604-52 Matrix: Drinking Water Sampled: 09/07/24 09:38:00									
<b>Metals</b>									
Lead	1.29		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm206 Lims Reference ID: AC30604-53 Matrix: Drinking Water Sampled: 09/07/24 09:38:00									
<b>Metals</b>									
Lead	2.03		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm206 Lims Reference ID: AC30604-54 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm207 Lims Reference ID: AC30604-55 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	3.94		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:52	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-02-Rm207 Lims Reference ID: AC30604-56 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	1.70		1	1.00	µg/L	09/25/24 18:34	09/26/24 09:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm114 Lims Reference ID: AC30604-57 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	8.65		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm114 Lims Reference ID: AC30604-58 Matrix: Drinking Water Sampled: 09/07/24 09:40:00									
<b>Metals</b>									
Lead	9.04		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm115 Lims Reference ID: AC30604-59 Matrix: Drinking Water Sampled: 09/07/24 09:40:00									
<b>Metals</b>									
Lead	167		5	5.00	µg/L	09/26/24 14:50	09/27/24 16:15	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: CSES-SO-01-Rm112 Lims Reference ID: AC30604-60 Matrix: Drinking Water Sampled: 09/07/24 09:41:00									
<b>Metals</b>									
Lead	23.9		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm112 Lims Reference ID: AC30604-61 Matrix: Drinking Water Sampled: 09/07/24 09:41:00									
<b>Metals</b>									
Lead	1.36		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm113 Lims Reference ID: AC30604-62 Matrix: Drinking Water Sampled: 09/07/24 09:42:00									
<b>Metals</b>									
Lead	6.67		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm113 Lims Reference ID: AC30604-63 Matrix: Drinking Water Sampled: 09/07/24 09:42:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm221 Lims Reference ID: AC30604-64 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	12.8		1	1.00	µg/L	09/26/24 14:50	09/27/24 15:00	JW1	EPA 200.8 (Dig)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
Epic Environmental Services, LLC [EPIC62]  
80 Fork Bridge Road  
Pittsgrove, NJ 08318  
(856) 205-1077  
jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-02-Rm221 Lims Reference ID: AC30604-65 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	1.30		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm222 Lims Reference ID: AC30604-66 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	3.82		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm222 Lims Reference ID: AC30604-67 Matrix: Drinking Water Sampled: 09/07/24 09:39:00									
<b>Metals</b>									
Lead	4.87		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm219 Lims Reference ID: AC30604-68 Matrix: Drinking Water Sampled: 09/07/24 09:40:00									
<b>Metals</b>									
Lead	1.08		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm219 Lims Reference ID: AC30604-69 Matrix: Drinking Water Sampled: 09/07/24 09:40:00									
<b>Metals</b>									
Lead	1.81		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm220 Lims Reference ID: AC30604-70 Matrix: Drinking Water Sampled: 09/07/24 09:47:00									
<b>Metals</b>									
Lead	1.96		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm220 Lims Reference ID: AC30604-71 Matrix: Drinking Water Sampled: 09/07/24 09:47:00									
<b>Metals</b>									
Lead	1.58		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm217 Lims Reference ID: AC30604-72 Matrix: Drinking Water Sampled: 09/07/24 09:47:00									
<b>Metals</b>									
Lead	1.55		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm217 Lims Reference ID: AC30604-73 Matrix: Drinking Water Sampled: 09/07/24 09:48:00									
<b>Metals</b>									
Lead	1.43		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:49	PL	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-SO-01-Rm218 Lims Reference ID: AC30604-74 Matrix: Drinking Water Sampled: 09/07/24 09:49:00									
<b>Metals</b>									
Lead	1.88		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm218 Lims Reference ID: AC30604-75 Matrix: Drinking Water Sampled: 09/07/24 09:50:00									
<b>Metals</b>									
Lead	2.43		1	1.00	µg/L	09/25/24 18:36	09/26/24 08:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm110 Lims Reference ID: AC30604-76 Matrix: Drinking Water Sampled: 09/07/24 09:50:00									
<b>Metals</b>									
Lead	1.57		1	1.00	µg/L	09/26/24 18:06	09/27/24 17:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm110 Lims Reference ID: AC30604-77 Matrix: Drinking Water Sampled: 09/07/24 09:50:00									
<b>Metals</b>									
Lead	2.18		1	1.00	µg/L	09/26/24 18:06	09/27/24 17:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm111 Lims Reference ID: AC30604-78 Matrix: Drinking Water Sampled: 09/07/24 09:50:00									
<b>Metals</b>									
Lead	2.60		1	1.00	µg/L	09/26/24 18:06	09/27/24 17:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm111 Lims Reference ID: AC30604-79 Matrix: Drinking Water Sampled: 09/07/24 09:51:00									
<b>Metals</b>									
Lead	1.95		1	1.00	µg/L	09/26/24 18:06	09/27/24 17:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm108 Lims Reference ID: AC30604-80 Matrix: Drinking Water Sampled: 09/07/24 09:51:00									
<b>Metals</b>									
Lead	1.37		1	1.00	µg/L	09/26/24 18:06	09/27/24 17:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm108 Lims Reference ID: AC30604-81 Matrix: Drinking Water Sampled: 09/07/24 09:52:00									
<b>Metals</b>									
Lead	2.18		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm109 Lims Reference ID: AC30604-82 Matrix: Drinking Water Sampled: 09/07/24 09:53:00									
<b>Metals</b>									
Lead	5.19		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:02	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-01-Rm109 Lims Reference ID: AC30604-83 Matrix: Drinking Water Sampled: 09/07/24 09:53:00									
<b>Metals</b>									
Lead	1.47		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm215 Lims Reference ID: AC30604-84 Matrix: Drinking Water Sampled: 09/07/24 09:56:00									
<b>Metals</b>									
Lead	1.54		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm215 Lims Reference ID: AC30604-85 Matrix: Drinking Water Sampled: 09/07/24 09:56:00									
<b>Metals</b>									
Lead	1.53		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm216 Lims Reference ID: AC30604-86 Matrix: Drinking Water Sampled: 09/07/24 09:57:00									
<b>Metals</b>									
Lead	1.94		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm216 Lims Reference ID: AC30604-87 Matrix: Drinking Water Sampled: 09/07/24 09:57:00									
<b>Metals</b>									
Lead	3.12		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm213 Lims Reference ID: AC30604-88 Matrix: Drinking Water Sampled: 09/07/24 09:59:00									
<b>Metals</b>									
Lead	4.63		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm213 Lims Reference ID: AC30604-89 Matrix: Drinking Water Sampled: 09/07/24 09:59:00									
<b>Metals</b>									
Lead	1.13		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm214 Lims Reference ID: AC30604-90 Matrix: Drinking Water Sampled: 09/07/24 10:00:00									
<b>Metals</b>									
Lead	1.74		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm214 Lims Reference ID: AC30604-91 Matrix: Drinking Water Sampled: 09/07/24 10:00:00									
<b>Metals</b>									
Lead	1.77		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:26	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School  
**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-SO-01-Rm106 Lims Reference ID: AC30604-92 Matrix: Drinking Water Sampled: 09/07/24 10:00:00									
<b>Metals</b>									
Lead	7.44		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm106 Lims Reference ID: AC30604-93 Matrix: Drinking Water Sampled: 09/07/24 10:00:00									
<b>Metals</b>									
Lead	1.51		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-WC-01-Hall3 Lims Reference ID: AC30604-94 Matrix: Drinking Water Sampled: 09/07/24 10:02:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-BF-01-Hall3 Lims Reference ID: AC30604-95 Matrix: Drinking Water Sampled: 09/07/24 10:02:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:06	09/27/24 18:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm212 Lims Reference ID: AC30604-96 Matrix: Drinking Water Sampled: 09/07/24 10:04:00									
<b>Metals</b>									
Lead	4.01		1	1.00	µg/L	09/26/24 18:08	09/27/24 18:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm212 Lims Reference ID: AC30604-97 Matrix: Drinking Water Sampled: 09/07/24 10:04:00									
<b>Metals</b>									
Lead	1.73		1	1.00	µg/L	09/26/24 18:08	09/27/24 18:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-WC-02-Hall4 Lims Reference ID: AC30604-98 Matrix: Drinking Water Sampled: 09/07/24 10:06:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-BF-02-Hall4 Lims Reference ID: AC30604-99 Matrix: Drinking Water Sampled: 09/07/24 10:06:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm253 Lims Reference ID: AC30604-AA Matrix: Drinking Water Sampled: 09/07/24 10:07:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:02	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-02-Rm253 Lims Reference ID: AC30604-AB Matrix: Drinking Water Sampled: 09/07/24 10:07:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm098 Lims Reference ID: AC30604-AC Matrix: Drinking Water Sampled: 09/07/24 10:08:00									
<b>Metals</b>									
Lead	1.30		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm098 Lims Reference ID: AC30604-AD Matrix: Drinking Water Sampled: 09/07/24 10:08:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm099 Lims Reference ID: AC30604-AE Matrix: Drinking Water Sampled: 09/07/24 10:10:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm099 Lims Reference ID: AC30604-AF Matrix: Drinking Water Sampled: 09/07/24 10:10:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm096 Lims Reference ID: AC30604-AG Matrix: Drinking Water Sampled: 09/07/24 10:12:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm096 Lims Reference ID: AC30604-AH Matrix: Drinking Water Sampled: 09/07/24 10:12:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm097 Lims Reference ID: AC30604-AI Matrix: Drinking Water Sampled: 09/07/24 10:13:00									
<b>Metals</b>									
Lead	1.97		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm097 Lims Reference ID: AC30604-AJ Matrix: Drinking Water Sampled: 09/07/24 10:13:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/26/24 18:08	09/27/24 19:31	PL	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: CSES-DW-01-Rm119</b>						<b>Lims Reference ID: AC30604-AT Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:19:00</b>	
<b>Metals</b>									
Lead	7.24		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:29	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-WC-02-Hall5L</b>						<b>Lims Reference ID: AC30604-AU Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:20:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:31	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-BF-02-Hall5L</b>						<b>Lims Reference ID: AC30604-AV Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:20:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:33	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-WC-01-Hall5R</b>						<b>Lims Reference ID: AC30604-AW Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:21:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:35	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-BF-01-Hall5R</b>						<b>Lims Reference ID: AC30604-AX Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:21:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:37	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-SO-01-Cafe</b>						<b>Lims Reference ID: AC30604-AY Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:23:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:42	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-WC-02-Hall6</b>						<b>Lims Reference ID: AC30604-AZ Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:24:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:44	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-BF-02-Hall6</b>						<b>Lims Reference ID: AC30604-BA Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:24:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:50	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: CSES-WC-02-Hall7</b>						<b>Lims Reference ID: AC30604-BB Matrix: Drinking Water</b>		<b>Sampled: 09/07/24 10:25:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:52	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-BF-02-Hall7 Lims Reference ID: AC30604-BC Matrix: Drinking Water Sampled: 09/07/24 10:25:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm094 Lims Reference ID: AC30604-BD Matrix: Drinking Water Sampled: 09/07/24 10:30:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm094 Lims Reference ID: AC30604-BE Matrix: Drinking Water Sampled: 09/07/24 10:30:00									
<b>Metals</b>									
Lead	9.93		1	1.00	µg/L	09/27/24 10:43	09/30/24 16:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm093 Lims Reference ID: AC30604-BF Matrix: Drinking Water Sampled: 09/07/24 10:31:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 17:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm093 Lims Reference ID: AC30604-BG Matrix: Drinking Water Sampled: 09/07/24 10:31:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:43	09/30/24 17:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm092 Lims Reference ID: AC30604-BH Matrix: Drinking Water Sampled: 09/07/24 10:33:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm092 Lims Reference ID: AC30604-BI Matrix: Drinking Water Sampled: 09/07/24 10:33:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm091 Lims Reference ID: AC30604-BJ Matrix: Drinking Water Sampled: 09/07/24 10:34:00									
<b>Metals</b>									
Lead	7.06		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm091 Lims Reference ID: AC30604-BK Matrix: Drinking Water Sampled: 09/07/24 10:34:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:16	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School  
**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-SO-02-Rm259 Lims Reference ID: AC30604-BL Matrix: Drinking Water Sampled: 09/07/24 10:35:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm259 Lims Reference ID: AC30604-BM Matrix: Drinking Water Sampled: 09/07/24 10:35:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm256 Lims Reference ID: AC30604-BN Matrix: Drinking Water Sampled: 09/07/24 10:36:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm256 Lims Reference ID: AC30604-BO Matrix: Drinking Water Sampled: 09/07/24 10:36:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm261 Lims Reference ID: AC30604-BP Matrix: Drinking Water Sampled: 09/07/24 10:37:00									
<b>Metals</b>									
Lead	10.7		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm261 Lims Reference ID: AC30604-BQ Matrix: Drinking Water Sampled: 09/07/24 10:37:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm258 Lims Reference ID: AC30604-BR Matrix: Drinking Water Sampled: 09/07/24 10:38:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm258 Lims Reference ID: AC30604-BS Matrix: Drinking Water Sampled: 09/07/24 10:38:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm090 Lims Reference ID: AC30604-BT Matrix: Drinking Water Sampled: 09/07/24 10:39:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:41	PL	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
 Epic Environmental Services, LLC [EPIC62]  
 80 Fork Bridge Road  
 Pittsgrove, NJ 08318  
 (856) 205-1077  
 jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CSES-DW-01-Rm090 Lims Reference ID: AC30604-BU Matrix: Drinking Water Sampled: 09/07/24 10:39:00									
<b>Metals</b>									
Lead	2.02		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-01-Rm089 Lims Reference ID: AC30604-BV Matrix: Drinking Water Sampled: 09/07/24 10:40:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-01-Rm089 Lims Reference ID: AC30604-BW Matrix: Drinking Water Sampled: 09/07/24 10:40:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm263 Lims Reference ID: AC30604-BX Matrix: Drinking Water Sampled: 09/07/24 10:41:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm263 Lims Reference ID: AC30604-BY Matrix: Drinking Water Sampled: 09/07/24 10:41:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-SO-02-Rm260 Lims Reference ID: AC30604-BZ Matrix: Drinking Water Sampled: 09/07/24 10:41:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CSES-DW-02-Rm260 Lims Reference ID: AC30604-CA Matrix: Drinking Water Sampled: 09/07/24 10:42:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	09/27/24 10:59	09/30/24 15:58	PL	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
Epic Environmental Services, LLC [EPIC62]  
80 Fork Bridge Road  
Pittsgrove, NJ 08318  
(856) 205-1077  
jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

**List of Certifications**

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012430604  
**LIMS Reference ID:** AC30604  
**EMSL Customer ID:** EPIC62

**Attention:** James Eberts  
Epic Environmental Services, LLC [EPIC62]  
80 Fork Bridge Road  
Pittsgrove, NJ 08318  
(856) 205-1077  
jeberts@epicenviro.com

**Project Name:** Cold Springs Elementary School

**Customer PO:** NJ DOE 24-1057C  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 09/13/2024 09:35  
**Reported:** 10/08/2024 13:24

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

ACS 0654

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077  
PHONE: 1-800-220-3675  
FAX: (856) 786-5974

Report To Contact Name: James Eberts Bill To Company: Epic Environmental Services, LLC

Company Name: Epic Environmental Services, LLC Attention To: James Eberts / Timothy Eberts

Street: 80 Fork Bridge Road Street: 80 Fork Bridge Road

City: Pittsgrove State/Province: NJ Zip/Postal Code: 08318 City: Pittsgrove State/Province: NJ Zip/Postal Code: 08318

Phone: 856-205-1077 Fax: Phone: 856-205-1077 Fax:

Project Name: Cold Springs Elementary School Email Results To: jeberts@epicenj.com; jeberts@epicenj.com

U.S. State where Samples Collected: NJ Number of Samples in Shipment: 154 Purchase Order: NJ-DOE (24-1057C)

Sample for Compliance? Yes  No  If yes, NPDES?  Other (Specify):

Samples Collected by: EMSL  Client  check one Sampled By (Signature): [Signature]

Standard Turnaround Time:  2 Weeks The following TATs are subject to Lab approval:  1 Week  4 Days  3 Days  1 Day Samples Received Chilled (Y/N)

Failure to complete will hinder processing of samples List Test(s) Needed

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA 200.8 Total Lead	Field pH	Field pH Test Time	Field Temp. Deg C	Field Temp. Test Time	Comments
CSES - FB	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9/7/24	W=Water S=Soil A=Air SL=Sludge O=Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	X					
WC-01-TRAIL 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0902	W		X					
BF-01-TRAIL 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0903	W		X					
SD-01-KIT 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0903	W		X					
SD-01-KIT 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0904	W		X					
Released By (Signature): [Signature]			Date & Time: 7/13/24 0940			Received By: [Signature]					Date & Time: 9/13/24 9:35am

Please indicate reporting requirements:  Results Only  Results and QC  Reduced Deliverables  Disk Deliverable  Other

Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

Receives



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

Environmental Chemistry  
Chain of Custody  
EMSL Order Number (Lab Use Only):  
ACS 58554

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
KE-01- KIT	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2							
SD-01- FAC	<input type="checkbox"/>	<input type="checkbox"/>	0906	W								
SD-01- RM119	<input type="checkbox"/>	<input type="checkbox"/>	0907	W								
DW-01- RM119	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0908	W								
SO-01- RM120	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0910	W								
DW-01- RM120	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0910	W								
SD-01- RM121	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0912	W								
DW-01- RM121	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0912	W								
SD-01- RM122	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
DW-01- RM122	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
SD-01- RM123	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
DW-01- RM123	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
SO-01- RM124	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
DW-01- RM124	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0913	W								
SD-01- RM125	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0914	W								
DW-01- RM125	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0914	W								
SO-01- RM126	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0915	W								

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):  
ACS0857

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
DW-01-EM126	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2	1						
SD-01-EM127	<input type="checkbox"/>	<input type="checkbox"/>	0916	W		1						
DW-01-EM127	<input type="checkbox"/>	<input type="checkbox"/>	0916	W		1						
SD-01-COPEY	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0917	W								
WC-01-HALL2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0918	W		1						
BF-01-HALL2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0918	W		1						
WC-01-GLR	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0920	W		1						
BF-01-GLR	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0920	W		1						
WC-01-BLR	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0921	W		1						
BF-01-BLR	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0921	W		1						
NS-01-NURSE	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0923	W		1						
SD-02-FAC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0923	W		1						
SD-02-EM200	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0925	W		1						
DW-02-EM200	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0925	W		1						
SD-02-EM200	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0925	W		1						
DW-02-EM201	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0925	W		1						
SD-02-EM203	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0927	W		1						

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

Environmental Chemistry  
Chain of Custody  
EMSL Order Number (Lab Use Only):  
AC380054

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Task(s) Needed				Comments	
							Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
DW-02-EM203	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24 0927	W	2							
SO-01-EM100	<input type="checkbox"/>	<input type="checkbox"/>	0927	W								
DW-01-EM100	<input type="checkbox"/>	<input type="checkbox"/>	0927	W								
SO-01-EM101	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0930	W								
DW-01-EM101	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0930	W								
SO-01-EM102	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0930	W								
DW-01-EM102	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0930	W								
SO-01-EM103	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0931	W								
DW-01-EM103	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0931	W								
SO-01-EM204	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0935	W								
DW-02-EM204	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0936	W								
SO-02-EM205	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0936	W								
DW-02-EM205	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0938	W								
SO-02-EM206	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0938	W								
DW-02-EM206	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W								
SO-02-EM207	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W								
DW-02-EM207	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W								

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):  
AC38604

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed						Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time				
SO-01-EM114	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2									
DW-01-EM114	<input type="checkbox"/>	<input type="checkbox"/>	0940	W										
SO-01-EM115	<input type="checkbox"/>	<input type="checkbox"/>	0940	W										
SO-01-EM112	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0941	W										
DW-01-EM112	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0941	W										
SO-01-EM113	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0942	W										
DW-01-EM113	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0942	W										
SO-02-EM221	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W										
DW-02-EM221	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W										
SO-02-EM222	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W										
DW-02-EM222	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0939	W										
SO-02-EM219	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0940	W										
DW-02-EM219	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0940	W										
SO-02-EM220	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0947	W										
DW-02-EM220	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0947	W										
SO-02-EM217	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0947	W										
DW-02-EM217	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0948	W										

(Lab) Received Temperature: \_\_\_\_\_ °C





EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):  
AC30654

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed						Comments		
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time					
SD-01-EM218	<input type="checkbox"/>	<input type="checkbox"/>	0949	W	2	1									
DW-01-EM218	<input type="checkbox"/>	<input type="checkbox"/>	0950	W		1									
SO-01-EM110	<input type="checkbox"/>	<input type="checkbox"/>	0950	W		1									
DW-01-EM110	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0950	W		1									
SO-01-EM111	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0950	W		1									
DW-01-EM111	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0951	W		1									
SO-01-EM108	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0951	W		1									
DW-01-EM108	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0952	W		1									
SO-01-EM109	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0953	W		1									
DW-01-EM109	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0953	W		1									
SO-02-EM215	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0956	W		1									
DW-02-EM215	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0956	W		1									
SO-02-EM216	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0957	W		1									
DW-02-EM216	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0957	W		1									
SO-02-EM213	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0959	W		1									
DW-02-EM213	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0959	W		1									
SO-02-EM214	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1000	W		1									

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):  
AC306087

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
CSSES- DW-02-2M214	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2	200.						
SO-01-2M106	<input type="checkbox"/>	<input type="checkbox"/>	1000	W								
DW-01-2M106	<input type="checkbox"/>	<input type="checkbox"/>	1000	W								
SO-01-2M107	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1001	W								not sampled - SAU
DW-01-2M107	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1001	W								not sampled - SAU
WC-01-4HRL3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1002	W								
BF-01-4HRL3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1002	W								
SO-02-2M212	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1004	W								
DW-02-2M212	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1004	W								
WSC-02-4HRL4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1006	W								
BF-02-4HRL4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1006	W								
SO-02-2M253	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1007	W								
DW-02-2M253	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1007	W								
SO-01-2M098	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1008	W								
DW-01-2M098	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1008	W								
SO-01-2M099	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1010	W								
DW-01-2M099	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1010	W								

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):

AC30609

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

CSES -

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
SD-01-EM096	<input type="checkbox"/>	<input type="checkbox"/>	10/12	W	2	1						
DW-01-EM096	<input type="checkbox"/>	<input type="checkbox"/>	10/12	W								
SD-01-EM097	<input type="checkbox"/>	<input type="checkbox"/>	10/13	W								
DW-01-EM097	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/13	W								
SD-02-EM255	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/15	W								
DW-02-EM255	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/15	W								
SD-02-EM252	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/16	W								
DW-02-EM252	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/16	W								
SD-02-EM257	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/17	W								
DW-02-EM257	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/17	W								
SD-02-EM254	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/18	W								
DW-02-EM254	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/18	W								
SD-01-EM119	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/19	W								
DW-01-EM119	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/19	W								
WC-02-HARLSL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/20	W								
BE-02-HARLSL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/20	W								
WC-01-HARLSL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/21	W								

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY / PRODUCTS / TRAINING

### Environmental Chemistry

### Chain of Custody

EMSL Order Number (Lab Use Only):

AC30609

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed						Comments					
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Field pH	Field pH Test Time		Field Temp Deg C	Field Temp Test Time			
BF-01-HALLSR	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2	1												
SO-01-CAFE	<input type="checkbox"/>	<input type="checkbox"/>	10/23	W														
WC-02-HALL6	<input type="checkbox"/>	<input type="checkbox"/>	10/24	W														
BF-02-HALL6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/24	W														
WC-02-HALL7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/25	W														
BF-02-HALL7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/25	W														
SO-01-PM094	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/30	W														
DM-01-PM094	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/30	W														
SO-01-PM093	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/31	W														
DM-01-PM093	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/31	W														
SO-01-PM092	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/35	W														
DM-01-PM092	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/33	W														
SO-01-PM091	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/34	W														
DM-01-PM091	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/34	W														
SO-02-PM259	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/35	W														
DM-02-PM259	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/35	W														
SO-02-PM256	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10/36	W														

(Lab) Received Temperature: \_\_\_\_\_ °C



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING  
EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

**Environmental Chemistry**  
**Chain of Custody**  
EMSL Order Number (Lab Use Only):  
435609

PHONE:  
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
	Comp	Grab					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
DW-02-EM256	<input type="checkbox"/>	<input type="checkbox"/>	9/7/24	W	2							
SD-02-EM261	<input type="checkbox"/>	<input type="checkbox"/>	1037	W								
DW-02-EM261	<input type="checkbox"/>	<input type="checkbox"/>	1037	W								
SD-02-EM258	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1038	W								
DW-02-EM258	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1038	W								
SD-01-EM090	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1039	W								
DW-01-EM090	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1039	W								
SD-01-EM089	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1040	W								
DW-01-EM089	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1040	W								
SD-02-EM263	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1041	W								
DW-02-EM263	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1041	W								
SD-02-EM260	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1042	W								
DW-02-EM260	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1042	W								
	<input type="checkbox"/>	<input checked="" type="checkbox"/>		W								
	<input type="checkbox"/>	<input checked="" type="checkbox"/>		W								
	<input type="checkbox"/>	<input checked="" type="checkbox"/>		W								
	<input type="checkbox"/>	<input checked="" type="checkbox"/>		W								

(Lab) Received Temperature: \_\_\_\_\_ °C

CSES-



The Gloucester City School District is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for drinking water locations throughout the school was performed on September 7, 2024. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse’s offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for, water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an “initial draw” sample was collected from the first water to come out of the outlet. After this sample was collected, water was allowed to flush for the required amount of time, and a second “flush” sample was collected. The purpose of the flush sample is to help determine if contamination does exist, whether it is originating from the outlet itself or from the building’s plumbing.

A summary of each location above the action level, as well as the short-term response, is found below:

### **Cold Springs School**

<b>SAMPLE LOCATION</b>	<b>FIRST DRAW RESULT</b>	<b>FLUSH SAMPLE RESULT</b>	<b>SHORT TERM RESPONSE</b>
Kettle Filler - Kitchen	<b>152 µg/L</b>	n/a	Hand Wash only sign
Sink – Room 200	<b>23.1 µg/L</b>	n/a	Hand Wash only sign
Sink – Room 201	<b>40.8 µg/L</b>	n/a	Hand Wash only sign
Sink – Room 115	<b>167 µg/L</b>	n/a	Hand Wash only sign
Sink – Room 112	<b>23.9 µg/L</b>	n/a	Hand Wash only sign

**Any location requiring corrective actions will be tested prior to being placed back into service.**